

TWIN CITY TESTING AND ENGINEERING LABORATORY, INC.**ENGINEERS AND CHEMISTS**

662 Cromwell Avenue - St. Paul, Minn. 55114

**REPORT OF: EXAMINATION OF SEWAGE AND INDUSTRIAL WASTE****PROJECT:****DATE:** December 29, 1969

REPORTED TO: Reilly Tar & Chemical Company
7200 Walker
(3) Minneapolis, Minnesota 55426

FURNISHED BY:**COPIES TO:**

US EPA RECORDS CENTER REGION 5



514882

LABORATORY No. 2-11667**SAMPLE IDENTIFICATION:**

Sample #A

RESULTS:

pH	8.0
Total Solids, ppm	214
Total Solids - Loss on ignition, ppm	18
Suspended Solids, ppm	18
Suspended Solids - Loss on ignition, ppm	6
Dissolved Solids, ppm	196
Settleable Solids, ml/L	0.1
Biochemical Oxygen Demand (5 day), ppm	140
Oil, ppm	1.6
Chlorides, ppm	16
Dissolved Oxygen, ppm	0.2
Chemical Oxygen Demand, ppm	56
Phenols, ppm	0.56

302456**REMARKS:** The sample was received for test December 19, 1969.

AS A MUTUAL PROTECTION TO CLIENTS, THE PUBLIC AND OURSELVES, ALL REPORTS ARE SUBMITTED AS THE CONFIDENTIAL PROPERTY OF CLIENTS. AND AUTHORIZATION FOR PUBLICATION OF STATEMENTS, CONCLUSIONS OR EXTRACTS FROM OR REGARDING OUR REPORTS IS RESERVED PENDING OUR WRITTEN APPROVAL.

Twin City Testing and Engineering Laboratory, Inc.

By